



NOTES:

1. J-BOLT DIAMETER:
  - PIPE DIAMETER LESS THAN OR EQUAL TO 6": 7/8", 6" & 8" PIPE: 1", 10" = 1-1/4".
  - PIPE DIAMETER GREATER THAN 12": 1-1/2".
2. TIGHTEN TOP NUTS TO TENSION BOLTS.
3. TIGHTEN LOWER NUTS TO COMPRESS CLAMP SNUG.



City of  
Bellevue

WATER UTILITY

**TITLE**

PIPE CLAMP AND ANCHOR RODS  
FOR CONCRETE BLOCKING

JANUARY 2011

NO SCALE

NO. W-5